



Product Approval
USER: Public User

[Product Approval Menu](#) > [Application Detail](#)

OFFICE OF THE
SECRETARY

FL #	FL17079-R2
Application Type	Revision
Code Version	2017
Application Status	Approved
Comments	
Archived	<input type="checkbox"/>
Product Manufacturer	Expert Shutter Services, Inc.
Address/Phone/Email	1626 SW Biltmore ST Port St. Lucie, FL 34984 (772) 871-1915 Ext 106 callexpert@aol.com
Authorized Signature	Michael Heissenberg callexpert@aol.com
Technical Representative	Michael Heissenberg
Address/Phone/Email	1626 SW Biltmore St Port St Lucie, FL 34984 (772) 871-1915 Ext 106 CallExpert@aol.com
Quality Assurance Representative	Michael Heissenberg
Address/Phone/Email	1626 SW Biltmore St Port St Lucie, FL 34984 (772) 871-1915 Ext 106 CallExpert@aol.com
Category	Impact Protective Systems
Subcategory	Operable
Compliance Method	Evaluation Report from a Florida Registered Architect or a Licensed Florida Professional Engineer <input type="checkbox"/> Evaluation Report - Hardcopy Received
Florida Engineer or Architect Name who developed the Evaluation Report	Walter A. Tillit Jr. P.E.
Florida License	PE-44167
Quality Assurance Entity	National Accreditation and Management Institute
Quality Assurance Contract Expiration Date	12/31/2019
Validated By	John Henry Kampmann Jr. <input checked="" type="checkbox"/> Validation Checklist - Hardcopy Received
Certificate of Independence	FL17079_R2_COI_EXPERT_SHUTTER_SERVICES_INC_DRWG_17-243_CERTIFICATION_OF_INDEPENDENCE.PDF
Referenced Standard and Year (of Standard)	Standard TAS 201, 202 & 203
	Year 1994
Equivalence of Product Standards Certified By	
Sections from the Code	

Product Approval Method

Method 1 Option D

Date Submitted 09/27/2017
Date Validated 10/19/2017
Date Pending FBC Approval 10/25/2017
Date Approved 12/12/2017

Summary of Products

FL #	Model, Number or Name	Description
17079.1	Nautilus Impact Protective Rolling System	Nautilus Impact Protective Rolling System
Limits of Use Approved for use in HVHZ: Yes Approved for use outside HVHZ: Yes Impact Resistant: Yes Design Pressure: +160/-160 Other: Missile level "D" wind zones 1, 2, 3 and 4 (basic protection only). Pressure rating: +160/-160 p.s.f. at 8'-0" span (wall mounted) with 1/2" slip. +30/-30 p.s.f. at 20'-0" span (wall mounted) with 1/2" slip. See sheets 15, 16, and 20 of installation drawing for additional pressures and spans.		Installation Instructions FL17079_R2_II_EXPERT SHUTTER SERVICES INC_DRWG 17-243.PDF Verified By: American Test Lab of South Florida Inc. Created by Independent Third Party: Yes Evaluation Reports FL17079_R2_AE_EXPERT SHUTTER SERVICES INC_DRWG 17-243_PRODUCT EVALUATION REPORT.PDF Created by Independent Third Party: Yes

[Back](#)

[Next](#)

[Contact Us](#) :: 2601 Blair Stone Road, Tallahassee FL 32399 Phone: 850-487-1824

The State of Florida is an AA/EEO employer. [Copyright 2007-2013 State of Florida.](#) :: [Privacy Statement](#) :: [Accessibility Statement](#) :: [Refund Statement](#)

Under Florida law, email addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact the office by phone or by traditional mail. If you have any questions, please contact 850.487.1395. *Pursuant to Section 455.275(1), Florida Statutes, effective October 1, 2012, licensees licensed under Chapter 455, F.S. must provide the Department with an email address if they have one. The emails provided may be used for official communication with the licensee. However email addresses are public record. If you do not wish to supply a personal address, please provide the Department with an email address which can be made available to the public. To determine if you are a licensee under Chapter 455, F.S., please click [here](#).

Product Approval Accepts:

